



## OHL Approved Meter Base List

<b>SINGLE POSITION METER BASE SELECTION TABLE</b>				
<b>SERVICE VOLTAGE (PHASE/WIRE)</b>	<b>SERVICE AMPERAGE</b>	<b>SOCKET TYPE</b>	<b>ANSI FORM TYPE</b>	<b>APPROVED MODELS</b>
120/240V (1PH 3W) <b>UNDERGROUND SERVICE</b>	<=200A	4 JAW	FORM 2S	MICRO ELECTRIC: BS2-TCV, BS2-INTCV HYDEL: EK400RO, EK200XL EATON: LM2, LM2-IN
120/240V (1PH 3W) <b>OVERHEAD SERVICE</b>	<=200A	4 JAW	FORM 2S	ANY 200A CSA APPROVED MODEL (IF LUG CONNECTION ELECTRICIAN MUST SUPPLY/INSTALL LUGS)
120/240V (1PH 3W)	400A	5 JAW	FORM 3S	EATON: TCC5-TH
120/208V NETWORK SERVICE (2PH 3W)	<=200A	5 JAW	FORM 12S	ANY CSA APPROVED MODEL
120/208V (3PH 4W) or 347/600V (3PH 4W)	<=200A	7 JAW	FORM 16S	ANY CSA APPROVED MODEL
120/208V (3PH 4W) or 347/600V (3PH 4W)	>=200A	13 JAW	FORM 9S	Contact Engineering Department

<b>MULTI POSITION METER BASE SELECTION TABLE</b>				
<b>SERVICE VOLTAGE (PHASE/WIRE)</b>	<b>SERVICE AMPERAGE</b>	<b>SOCKET TYPE</b>	<b>ANSI FORM TYPE</b>	<b>APPROVED MODELS</b>
120/240V (1PH 3W) <b>UNDERGROUND SERVICE</b>	<=200A	4 JAW	FORM 2S	MICRO ELECTRIC: BDA2-V EATON: 2K2, 2K2-IN, 3K2, 3K2-IN, 2K4, 2K4-IN, 3K4, 3K4-IN
120/240V (1PH 3W) <b>OVERHEAD SERVICE</b>	<=200A	4 JAW	FORM 2S	ANY 200A CSA APPROVED MODEL (IF LUG CONNECTION ELECTRICIAN MUST SUPPLY/INSTALL LUGS)

1. The 5th jaw on the socket must be installed in the 9 o'clock position.
2. Automatic by-pass device on the left side.
3. The maximum number of meter base positions on underground services is three.
4. Multiple position meter bases for underground services must have a blank compartment.
5. All Meterbases must be compliant with ESA Bulletin 10-15-9.